

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1574:142 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** ADT Security Service, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004-1561  
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

**DESIGN:** Models ADTGC-VM and ADTGCF-VM, multiple candela synchronizable strobe lights. The lights are only considered synchronized when used in conjunction with listed Model ADTG1M-RM (CSFM Listing No. 7300-1574:103) sync module, which may employ Model SIGA-CC1S (CSFM Listing No. 7300-1574:113) Auto Sync Output Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 16-33 VDC/vFWR  
Candela: 15cd, 30cd, 75cd, or 95cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. For indoor use only and wall or ceiling mount.

**MARKING:** Listee's name, model number, electrical/candela rating, and UL label.

**APPROVAL:** Listed as strobe lights for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLF:** 7125-1591:219

02-11-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**FEBRUARY 11, 2004**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager